



City of Lake City

DEPARTMENT OF GROWTH MANAGEMENT

205 NORTH MARION AVENUE
LAKE CITY, FLORIDA 32055

TELEPHONE: (386) 719-5748
FAX: (386) 758-5426

12-3-09

To Whom it may concern:

Re: Hallways located on first floor Lake Shore Hospital Authority
Located at 259 N.E. Franklin St.

From Troy Crews
Chief Building Inspector

Upon Inspection of 2 hallways located on the first floor of said building the following was noted. The first hall to the East end of the building that leads to offices measures 44 inches in width which meets Florida Building code section 1017.2 Corridor Width not less than 44 inches (exception # 2 allows 36 inch minimum for hallways serving an occupant load of less than 50), which would be the case for this hallway. The second hallway to the west from foyer area measures 35 inches in width, it however is not part of an accessible route therefore it does not have to comply with Florida Accessibility Code. In regards to The Florida Building Code 1017.2 exception # 1 allows a 24-inch minimum for access to electrical or mechanical equipment. Copy of code is attached. If you have any questions feel free to call me.

Sincerely Troy Crews